

LICENCE

No. 21056

Issued to:

Applicant:

Italian Cable Company S.p.A.

Via Francesca 8

24060 BOLGARE (BG)

Italy

Licensee:

Italian Cable Company S.p.A.

Via Francesca 8

24060 BOLGARE (BG)

Italy



Product : cables for fixed wiring

Trade name(s) : ICC

Type(s)/model(s) : XVB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 258

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 20/11/2018

ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

| | | |
|---------------------|---|----------------------------------|
| Product | : | cables for fixed wiring |
| Trade name(s) | : | ICC |
| Type(s)/Model(s) | : | XVB |
| description | : | cable with unarmoured conductors |
| insulating material | : | XLPE insulated and PVC sheathed |
| rated voltage Uo/U | : | 0.6/1 kV |
| Fire propagation | : | minimum Cca-s3,d2,a3 |

Additional information

Covered number of conductors (Round type) and cross sections

2-core: 1.5 mm² to 35 mm²
 3 -core: 1.5 mm² to 50 mm²
 4-core: 1.5 mm² to 50 mm²
 5-core: 1.5 mm² to 25 mm²
 3-core: 25 mm² to 35 mm² + 1-core: 16 mm²
 3-core: 50 mm² + 1-core: 25 mm²

Covered number of conductors (Sector type) and cross sections

3 -core: 70 mm² to 150 mm²
 4-core: 70 mm² to 185 mm²
 3-core: 70 mm² + 1-core 35 mm²
 3-core: 95 mm² + 1-core: 50 mm²
 3-core: 120 mm² to 150 mm² + 1-core: 70 mm²
 3-core: 185 mm² + 1-core: 95 mm²

TESTS

Test requirements

NBN HD 604:2016 + Corrigendum 2017-01 + AC 2018-08

Test results

The test results are laid down in test certification file ref.616606/01

Remarks


This certificate is based on test reports ref. 616606/01a, 616606/01b, 616606/01c and 616606/01d

Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 20/11/2018

Certification Manager :

A handwritten signature in blue ink, followed by the date '2018-11-20'.

FACTORY LOCATION(S)

Italian Cable Company S.p.A.
Via Francesca 8
24060 BOLGARE (BG)
Italy